



NOTES:

1. BACKFLOW PREVENTER(S) FOR WATER FIRE SPRINKLER SYSTEMS SHALL BE:
  - A) 3/4 INCH TO 2 INCH = ASSE 1024 OR COUNTY APPROVED EQUAL
  - B) 2 1/2 INCH AND ABOVE = ASSE 1015
2. BACKFLOW PREVENTER(S) FOR DOMESTIC SHALL BE ASSE 1024.
3. LINE 2" AND BELOW IS CURB STOP, ANYTHING 2" AND ABOVE IS GATE VALVE.



**CHARLES COUNTY GOVERNMENT**

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022

CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE

h.B.W. Oct 5, 2022

PROFESSIONAL ENGINEER DATE

STANDARD DETAIL

**FIRE SPRINKLER & DOMESTIC SYSTEM CONNECTION (INDIVIDUAL/ RESIDENTIAL) FOR EXISTING ONLY INSIDE METER**

W

**1.02**

REVISIONS:

JANUARY 2007  
SEPTEMBER 2022