



CONCRETE VALVE BOX COLLAR

- NOTES:
- (1) ALL VALVES SHALL BE RESILENT WEDGE AWWA C-509 AND AWWA C-515.
  - (2) PROVIDE CONCRETE COLLAR FOR VALVE BOXES IN UNPAVED AREAS.



**CHARLES COUNTY GOVERNMENT**  
 DEPARTMENT OF PLANNING & GROWTH MANAGEMENT  
 APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022  
Raymond N. Shumaker, Jr. (Oct 5, 2022 12:20 EDT)  
 CHIEF OF CODES, PERMITS, & INSPECTION SERVICES  
 DATE  
 Oct 5, 2022  
 PROFESSIONAL ENGINEER DATE

STANDARD DETAIL

DETAIL OF GATE VALVE & BOX 16" & BELOW

W 3.00
REVISIONS:
JUNE 1995
SEPTEMBER 2022