



SECTION

NOTE:

1. VAULTS FOR ELECTRICALLY OPERATED VALVES SHALL BE BUILT WATERTIGHT AND REQUIRE A SUMP PUMP AND FLOOD ALARM CONNECTED TO SCADA. SUBMIT DETAILS FOR REVIEW.



CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022
Raymond N. Shumaker, Jr. (Oct 5, 2022 12:20 EDT)

CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE
HLB Oct 5, 2022

PROFESSIONAL ENGINEER

DATE

STANDARD DETAIL

16" & 20" VERTICAL VALVES INSTALLATION

W

3.06

REVISIONS:

JUNE 1995

SEPTEMBER 2022