

NOTES:

- 1. RESTRAIN ALL JOINTS ON 6" BLOWOFF PIPING, SEE SPECIFICATIONS.
- 2. SET VALVE BOX AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON CONTRACT DRAWINGS.
- 3. MANHOLE SHALL BE LOCATED AS SHOWN UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
- 4. PROVIDE V-BIO POLYETHYLENE ENCASEMENT.

