



**TYPE 'B' BLOWOFF—FOR MAINS  
36" AND LARGER**

**NOTES:**

1. RESTRAIN ALL JOINTS ON 6" BLOWOFF PIPING, SEE SPECIFICATIONS.
2. SET VALVE BOX AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON CONTRACT DRAWINGS.
3. MANHOLE SHALL BE LOCATED AS SHOWN UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
4. PROVIDE V-BIO POLYETHYLENE ENCASEMENT.



**CHARLES COUNTY GOVERNMENT**

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022  
Raymond N. Shumaker, Jr. (Oct 5, 2022 12:20 EDT)

CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE  
Professional Engineer Signature Oct 5, 2022

PROFESSIONAL ENGINEER

DATE

**STANDARD DETAIL**

**TYPE "B" BLOWOFF FOR  
MAINS 36" AND LARGER**

**W**

**5.03**

REVISIONS:

JUNE 1995

SEPTEMBER 2022