


SECTION 'A-A'

NOTE: CARRY ALL BEARING SURFACES TO UNDISTURBED GROUND OR FIRM SUBGRADE.



ROTATE 6" x 6" MJ TEE(UP) FOR BLOCKING, SEE DETAIL THIS SHEET. STRAP VALVES, SEE DETAIL / . .

TYPICAL PROFILE FOR MODIFIED TYPE 'B' BLOWOFF—FOR MAINS 36" AND LARGER



CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022

CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE

[Signature] Oct 5, 2022

PROFESSIONAL ENGINEER DATE

STANDARD DETAIL

MODIFIED TYPE "B"
BLOWOFF FOR MAINS 36"
AND LARGER

W
5.04

REVISIONS:
JUNE 1995
SEPTEMBER 2022