

- 1. REFER TO STANDARD DETAIL W6.05 WHEN METER 4. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL AREA IS ADJACENT TO AN EXTERIOR WALL.
- 2. METER TO BE SET HORIZONTALLY.
- 3. NOMINAL DIMENSION: 3"METER: 1-3 FT 4" AND LARGER METER: 1-2 FT
- 5. TURBULENCE COMPENSATOR MIN. 5 PIPE DIA. INLET AND OUTLET.
- 6. METER BOTTOM TO BE SET BY PLUMBER. COUNTY WILL SET METER HEAD AND RADIO. COUNTY ISSUES METER.
- 7. TYPE OF PIPE MATERIAL TO BE OTHER THAN PLASTIC.

