



NOTES:

1. REFER TO STANDARD DETAIL W6.08 WHEN METER AREA IS NOT ADJACENT TO AN EXTERIOR WALL.
2. METER TO BE SET HORIZONTALLY.
3. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL DISTRIBUTION EQUIPMENT.
4. TURBULENCE COMPENSATOR MIN. 5 TIMES PIPE DIA. INLET AND OUTLET.
5. METER BOTTOM TO BE SET BY PLUMBER. COUNTY WILL SET METER HEAD AND RADIO. COUNTY ISSUES METER.
6. CROSS CONNECTION CONTROL IS REQUIRED.



CHARLES COUNTY GOVERNMENT
 DEPARTMENT OF PLANNING & GROWTH MANAGEMENT
 APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022
Raymond N. Shumaker, Jr. (Oct 5, 2022 12:20 EDT)
 CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE
J.B.M. Oct 5, 2022
 PROFESSIONAL ENGINEER DATE

STANDARD DETAIL

 INDOOR F.M. METER INSTALLATIONS

W
6.07
REVISIONS:
JUNE 1995
SEPTEMBER 2022