


- NOTES:
1. REFER TO STANDARD DETAIL W6.07 WHEN METER AREA IS ADJACENT TO AN EXTERIOR WALL.
 2. METER TO BE SET HORIZONTALLY.
 3. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL DISTRIBUTION EQUIPMENT.
 4. TURBULENCE COMPENSATOR MIN. 5 TIMES PIPE DIA. INLET AND OUTLET.
 5. METER BOTTOM TO BE SET BY PLUMBER. COUNTY WILL SET METER HEAD AND RADIO. COUNTY ISSUES METER.
 6. CROSS CONNECTION CONTROL IS REQUIRED.



CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: *Rachael W. Swinicki, Jr.* Oct 5, 2022

CHIEF OF CODES, PERMITS, & INSPECTION SERVICES

DATE: Oct 5, 2022
 PROFESSIONAL ENGINEER

STANDARD DETAIL

INDOOR F.M. METER INSTALLATIONS

W
6.08

REVISIONS:	JUNE 1995
	SEPTEMBER 2022