



NOTES:

1. METER TO BE SET HORIZONTALLY.
2. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL DISTRIBUTION EQUIPMENT.
3. TURBULENCE COMPENSATOR MIN. 5 TIMES PIPE DIA. INLET AND OUTLET.
4. METER BOTTOM TO BE SET BY PLUMBER. COUNTY WILL SET METER HEAD AND RADIO. COUNTY ISSUES METER.
5. CROSS CONNECTION CONTROL IS REQUIRED.
6. TYPE OF PIPE MATERIAL TO BE OTHER THAN PLASTIC.



CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: Raymond N. Shumaker, Jr. Oct 5, 2022
Raymond N. Shumaker, Jr. (Oct 5, 2022 12:20 EDT)

CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE
H.B.M. Oct 5, 2022

PROFESSIONAL ENGINEER DATE

STANDARD DETAIL

INDOOR DETECTOR CHECK METER INSTALLATIONS

W
6.09

REVISIONS:
JUNE 1995
SEPTEMBER 2022