



USE SCHEDULE 40 PVC PIPE AND FITTINGS } LARGER AS DIRECTED BY  
MINIMUM 2000 GALLON GREASE TRAP } WATER / SEWER ENGINEER  
UPON REVIEW OF MENU ITEMS

TANK AND ALL COMPONENTS SHALL BE DESIGNED FOR TRUCK LOADINGS (H-20).

**NOTES :**

1. PROVIDE STRAPPING ON INTERIOR VERTICAL CLEANOUT STACK STARTING AT 6 IN ON EACH END OF PIPE AND EVERY 3.0 FT. MUST BE STAINLESS STEEL.
2. MINIMUM 42 IN COVER ON SEWER PIPE. ANYTHING BELOW THE MINIMUM COVER MUST BE APPROVED BY THE COUNTY.
3. THE OUTFALL PIPE TO BE MINIMUM 3 IN LOWER THAN THE INFLOW PIPE.
4. CLEANOUT CAP TOP MINIMUM 12 IN BELOW FINISHED GRADE.
5. DRILL A 3/8 IN HOLE IN CLEANOUT CAP.
6. NO BAFFLE ALLOWED.



**CHARLES COUNTY GOVERNMENT**

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: Raymond N. Shumaker, Jr. Aug 8, 2023  
CHIEF OF CODES, PERMITS, & INSPECTION SERVICES DATE

Andy K. Chin Aug 8, 2023  
PROFESSIONAL ENGINEER DATE

STANDARD DETAIL

OUTSIDE GREASE TRAP  
(INTERCEPTOR)

S  
5.04

REVISIONS:  
DECEMBER 2022