



TYPICAL

NOTES:

1. FOR 16" THRU 30" DIAMETER, INSTALL RETAINER GLANDS ON DUCTILE IRON PIPE.
2. INSTALL RETAINER GLAND IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
3. USE APPROVED RETAINER GLANDS, SEE SPECIFICATIONS.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: *[Signature]* 6/29/95
DIRECTOR OF DEVELOPMENT SERVICES DATE

[Signature] 6/29/95
WATER / SEWER ENGINEER DATE

STANDARD DETAIL
 MECHANICAL JOINT
 RETAINER GLAND

REVISIONS:

B
2.04

97