



SPECIFICATIONS

NOMIAL PIPE SIZE (INCHES)	NUMBER OF MEGALUGS	TOTAL PRESSURE (PSI)	NUMBER OF T BOLTS
3	2	350	4
4	2	350	4
6	3	350	6
8	4	350	6
10	6	350	8
12	8	350	8
14	10	350	10
16	12	350	12
18	12	250	12
20	14	250	14
24	16	250	16
30	20	250	20

NOTES:

1. MECHANICAL JOINT FITTINGS ONLY.
2. MEGALUG™ OF EBAA IRON, INC. FOR INSTALLATION ON DUCTILE IRON PIPE ONLY.
3. INSTALLATIONS SHALL BE AS PER MANUFACTURER'S RECOMMENDATIONS.
4. TOTAL PRESSURE EQUAL TO OPERATING PRESSURE + SURGE PRESSURE.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

DIRECTOR OF DEVELOPMENT SERVICES DATE

*[Signature]* 6/29/95  
*[Signature]* 6/29/95  
 WATER / SEWER ENGINEER DATE

STANDARD DETAIL

MEGALUG™  
 MECHANICAL JOINT  
 RESTRAINING DETAIL

REVISIONS:

B  
 2.05

98